

Riverbank Acoustical Laboratories (RAL)TM / An Alion Science Technical Center
 Laboratory Measurement of Airborne Sound Transmission Loss
 of Building Partitions ASTM E 90-04/NVLAP 08/P06

TEST NUMBER: TL07-022 TEST DATE: JANUARY 23, 2007

CLIENT: Quiet Solution, LLC
 DESIGNATION: ID 02: QuietRock 510 24"oc WS wall w/ R-13 fiberglass and QuietRock 510

DIMENSIONS: 97" wide x 108" high x 4.625" thick
 AREA: 72.5 ft² (Filler: 53.5 ft² Comp: 126.0 ft²)
 WEIGHT: 390.75 lbs AREA WEIGHT: 5.37 lbs/ft²
 SPECIMEN DETAILS:

SOURCE ROOM: Room 2 Volume = 6297.6 ft³ Area = 2066.2 ft²
 RECEIVE ROOM: Room 1 Volume = 6254.5 ft³ Area = 2042 ft²
 FILE NAME: TL07_022_070123_A.doc

FREQ. (Hz)	T.L. (dB)	UNC. (dB) 95%CL	DEF. (dB) <CONT	FREQ. (Hz)	T.L. (dB)	UNC. (dB) 95%CL	DEF. (dB) <CONT
100	22	1.12		800	53	0.13	1
125	30	0.72	6	1k	55	0.14	
160	31	0.49	8	1.25k	56	0.13	
200	36	0.44	6	1.6k	57	0.11	
250	42	0.33	3	2k	59	0.11	
315	45	0.31	3	2.5k	61	0.06	
400	49	0.32	2	3.15k	62	0.05	
500	51	0.18	1	4k	63	0.08	
630	52	0.14	1	5k	61	0.05	

Sound Transmission Class (STC) = 52

Total Deficiencies = 31

Extended Frequency Data


FREQ.	T.L.	UNC.	DEF.	FREQ.	T.L.	UNC.	DEF.
40	25	0.71		6.3k	60	0.08	
50	18	0.66		8k	64	0.05	
63	13	0.51		10k	69	0.27	
80	18	0.66					

R: 51
 OITC: 34

Test Conducted by: Dean Victor

This single report page and accompanying graph contain the instantaneous raw data as provided to the client after testing of the specimen. This data, although accurate, is incomplete without the full specimen description, mounting details and signature pages. The full report referenced by the RAL test number above should be consulted for further information regarding these results.

SOUND TRANSMISSION REPORT
RAL - TL07-022



STC = 52



TRANSMISSION LOSS
SOUND TRANSMISSION LOSS CONTOUR